
SEIKO DIGITAL QUARTZ

Cal. A547A

Cal. A547A







4001 765



4216 765



☆4225 765



4246 766



4270 765



4313 765

4313 766



4398 765



4457 765



☆4510 750



4521 800



4530 649



☆ Maxell SR726W



022 446

2/1

Cal. A547A

Characteristics

Casing diameter:

Maximum height:

φ 27.0 mm 3.2 mm without battery

Frequency of quartz crystal oscillator: 32,768 Hz (Hz=Hertz.... . Cycles per second)

Time and calendar display: Hour, minute, second, date and day of the week can be displayed in 12-hour indication or 24-hour indication. (The month is displayed only when the calendar is adjusted.)

Alarm diaplay: Can be set to operate at any desired hour and minute.

Timer display: Can be set to operate at any desired minute up to 60 minutes.

Stop watch display: Digital Display System showing 12-hour, minute, second and 1/100 second.

Quick function change: Each of the above functions can be selected by simply depressing the appropriate quick-selection

button below the display panel.

Time signal: Can be set to ring every hour on the hour.

Regulation system: Trimmer condenser

Illuminating light: Illuminates all the digital displays in the dark by depressing the light button.

Battery life indicator: All the digits in the display begin flashing.

PART NO.	PART NAME	PART NO.	PART NAME
4001 765 4216 765 4225 765 4246 766 4270 765 4313 766 4313 766 4398 765 4457 765 4457 765 4510 750 4521 800 4530 649 022 446 ★Maxell SR726₩	Circuit block Insulator for circuit block Battery clamp Buzzer lead terminal Battery connection (—) Connector A Connector B Liquid crystal panel frame Circuit block cover Liquid crystal panel Reflecting mirror Bulb Circuit block screw Silver oxide battery		

Remarks:

The parts for the front switch portion are the casing parts.

Check the case number and refer to "SEIKO Quartz Casing Parts List" to choose an apropriate front switch unit.

Battery clamp

★4225 765 ·······Some models are not provided.

Liquid crystal panel


be matched according to the "SEIKO Quartz Casing Parts List."

☆ Maxell SR726W······The substitutive battery might be added to the applied battery in the future. In that case, please refer to separate "BATTERY LIST FOR SEIKO QUARTZ WATCHES".

TECHNICAL GUIDE

SEIKO DIGITAL QUARTZ

CAL. A547A




CONTENTS

١.	SPECIFICATIONS	1
Н,	STRUCTURE OF THE CIRCUIT BLOCK	1
Ш.	DISPLAY FUNCTION	2
IV.	DISASSEMBLING, REASSEMBLING AND LUBRICATING	3
	1. Disassembling, reassembling and lubricating of the case	3
	2. Disassembling and reassembling of the module	5
	3. Relationship between the segment (Liquid Crystal Panel Electrode) and the C-MOS-LSI output terminal	6
V.	CHECKING AND ADJUSTMENT	7
	Check battery voltage	7
	Check battery conductivity	7
	Check current consumption	7
	Check water resistance	8
	Check contact between C-MOS-LSI and Liquid crystal panel	8
	Check liquid crystal panel and circuit block	8
	Check accuracy	8
	Check functioning and adjustment	8
	Check alarm test system	8
	Check conductivity of switch components	9
	Check alarm condition	9
	Check bulb condition	9
	Check functioning	10

I. SPECIFICATIONS


Cal. No.	A547A			
Display medium	Nematic Liquid Crystal, FEM (Field Effect Mode)			
Liquid crystal driving system	Multiplex driving system			
Display system	 Time and calendar function (12 or 24 hour indication) Alarm function (12 or 24 hour indication) Stopwatch function Timer function 			
Additional mechanism	Battery life indicator Pattern segment checking system Illuminating light			
Loss/gain	Loss/gain at normal temperature range Monthly rate: less than 15 seconds (Annual rate: less than 3 minutes)			
Outside diameter	φ28.5 mm			
Height	3.6 mm			
Regulation system	Trimmer condenser			
Measuring gate by Quartz Tester	Any gate is available.			
Battery .	Maxell SR726W Battery Life is approximately 2 years. Voltage: 1.55V			

II. STRUCTURE OF THE CIRCUIT BLOCK



-1-

III. DISPLAY FUNCTION



IV. DISASSEMBLING, REASSEMBLING AND LUBRICATING

1. Disassembling, reassembling and lubricating of the case

- Disassembling procedures Figs.:
- Lubricating

Reassembling procedures Figs.:

Silicone grease 500,000 c.s.




(1) Casebezel


Remarks for reassembling the case back

The case back of the regular model other than the SPORTS 100 type model is of snap type case construction.

Be sure to align the mark " A " of the case back and that of the casebezel.











Disassembling of the front button portion

Push the front button portion with tweezers or screwdriver and remove it.






Reassembling of the front button portion

Reassembling procedures Figs.: (1) → (5)






2. Disassembling and reassembling of the module


Disassembling procedures Figs.:

Reassembling procedures Figs.:



3. Relationship between the segment (Liquid Crystal Panel Electrode) and the C-MOS-LSI output terminal

A complete knowledge of how the segment (Liquid Crystal Panel Electrode) works with the C-MOS-LSI output terminal will provide the proper procedures for checking and adjustment.



V. CHECKING AND ADJUSTMENT

Procedure

CHECK BATTERY VOLTAGE


Result:

More than 1.5V: Normal Less than 1.5V: Defective

CHECK BATTERY CONDUCTIVITY

CHECK CURRENT CONSUMPTION


- 1. Current consumption for the whole of the module
- It is possible to check the current consumption in any functions.



Result:

Less than 1.3µA: Normal More than 1.3µA: Defective Check the current consumption for the circuit block alone.

2. Current consumption for the circuit block alone



Result:

Less than 1.3 μ A: Normal More than 1.3 μ A: Defective

Procedure


CHECK WATER RESISTANCE

Note: When the water resistance is poor, water may have entered the front button portion. Disassemble the the front button portion for repairing.

CHECK CONTACT BETWEEN C-MOS-LSI AND LIQUID CRYSTAL PANEL

CHECK LIQUID CRYSTAL PANEL AND CIRCUIT BLOCK

- · Check the liquid crystal panel.
- Check the circuit block output voltage.



CHECK ACCURACY

Check the watch for accuracy in the daily rate measuring function with all the segments displayed. Depress button A to activate the setting function and then depress buttons B and C at the same time, and all the segments lights up. At this time, the alarm rings every second.

Check the accuracy by using the electromagnetic microphone in the same manner as for the analogue quartz watches.

CHECK FUNCTIONING AND ADJUSTMENT

CHECK ALARM TEST SYSTEM


Depress buttons B and C at once in the time and calendar function or the alarm function.


Procedure

CHECK CONDUCTIVITY OF SWITCH COMPONENTS

CHECK ALARM CONDITION

(1) Check to see if there is any contamination on the connecting portion of the piezoelectric element on the case back and the buzzer lead terminal. Also, check to see if there is seen a deformation on the buzzer lead terminal






Limit the protrusion of the buzzer lead terminal from the module to approx. 3mm.

(2) Measure the upconverter coil resistance of the circuit block and check it for broken wire and short circuit,

Range to be used: OHMS R x 1



Result: $45\Omega \sim 70\Omega$: Normal Less than 45Ω — Deffective More than 70Ω — (Broken wire)

Apply the probes of the Volt-ohm-meter to the wire terminal of the upconverter coil.

CHECK BULB CONDITION

* How to replace the bulb

Be sure to use the soldering iron of low heat capacity with as fine a tip as possible.

Thickness of the tip: Approx. \$\phi 1 mm

Heat capcity: 5W ~ 20W of power consumption

(1) Remove the defective bulb.

Hold the defective bulb gently with tweezers, apply the soldering iron to the bulb lead terminal and lift the lead of the bulb to remove it.

Procedures (2) The lead of the bulb is made somewhat longer. Out it off properly with nippers. Approx, 2mm (3) Solder the new bulb. Note: If the soldering iron is applied too long, the circuit block may be damaged. Be sure to apply the soldering iron to such an extent that the solder is melted uniformly at the connection (for approx. 1 second). Correct Excessive Insufficient (4) Finally check the bulb condition again. CHECK FUNCTIONING

All procedures of Disassembling, Reassembling, Checking and Adjustment are completed.